

**MSDH BUREAU OF PUBLIC WATER SUPPLY
VIOLATIONS - 2020**

All violations in this report must be reported on the CCR.

MS0250008 - CITY OF JACKSON

VIOLATION	FACILITY	VIOLATION PERIOD / DATE	CONTAMINANT OR RULE	PUBLIC NOTICE
45 - FAILURE ADDRESS DEFICIENCY (IESWTR)		02/13/2020	IESWTR	COMPLETE
43 - SINGLE COMB FLTR EFFLUENT (IESWTR/LT1)		01/01/2020 - 01/31/2020	TURBIDITY	COMPLETE
44 - MONTHLY COMB FLTR EFFLUENT (IESWTR/LT1)		01/01/2020 - 01/31/2020	TURBIDITY	COMPLETE
59 - WQP LEVEL NON-COMPLIANCE (LCR)		01/01/2020 - 06/30/2020	LEAD & COPPER RULE	COMPLETE
43 - SINGLE COMB FLTR EFFLUENT (IESWTR/LT1)	TF082	02/01/2020 - 02/29/2020	TURBIDITY	COMPLETE
41 - FAILURE MAINTAIN MICROBIAL TREAT.(LT2)	TF083	03/01/2020 - 03/31/2020	LT2ESWTR	COMPLETE
41 - FAILURE MAINTAIN MICROBIAL TREAT.(LT2)	TF083	05/01/2020 - 05/31/2020	LT2ESWTR	COMPLETE
59 - WQP LEVEL NON-COMPLIANCE (LCR)		07/01/2020 - 12/31/2020	LEAD & COPPER RULE	COMPLETE
41 - FAILURE MAINTAIN MICROBIAL TREAT.(LT2)	TF083	10/01/2020 - 10/31/2020	LT2ESWTR	COMPLETE
02 - MCL, LRAA	IDSE	10/01/2020 - 12/31/2020	TOTAL HALOACETIC ACIDS (HAA5)	COMPLETE